

Warren Peppard
Head of Development Management
Lincolnshire County Council
County Offices
Newland
Lincoln LN1 1YL
Tel: 01522 782070
developmentmanagement@lincolnshire.gov.uk

To: East Lindsey District Council

Application Ref: S/079/01078/22

Proposal: **Planning Permission - Installation of a temporary ground mounted 49.9MW solar farm with associated infrastructure, construction of vehicular accesses, CCTV cameras on 2.5m high poles a 15m high communications tower and security fencing to a maximum height of 2.2m.**

Location: **Land adjacent Sotby Woods, Sturton Road, Hatton**

With reference to the above application received 30 June 2022

Notice is hereby given that the County Council as Local Highway and Lead Local Flood Authority:

Requests that any permission given by the Local Planning Authority shall include the conditions below.

CONDITIONS (INCLUDING REASONS) /REASONS FOR REFUSAL

Highway Informative 03

The permitted development requires the formation of a new/amended vehicular access to the substation and solar farm. These works will require approval from the Highway Authority in accordance with Section 184 of the Highways Act. The works should be constructed in accordance with the Authority's specification that is current at the time of construction. Relocation of existing apparatus, underground services or street furniture will be the responsibility of the applicant, prior to application. For application guidance, approval and specification details, please visit <https://www.lincolnshire.gov.uk/licences-permits/apply-dropped-kerb> or contact vehiclecrossings@lincolnshire.gov.uk

Highway Informative 08

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works. For further guidance please visit our website via the following links:

Traffic Management - <https://www.lincolnshire.gov.uk/traffic-management>

Licences and Permits - <https://www.lincolnshire.gov.uk/licences-permits>

Highway Condition 33

The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall first have been approved in writing by the Local Planning Authority.

The scheme shall:

- be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
- provide flood exceedance routing for storm event greater than 1 in 100 year;
- provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
- provide attenuation details and discharge rates which shall be restricted to 1.4 litres per second;
- provide details of the timetable for and any phasing of implementation for the drainage scheme; and
- provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.

No dwelling shall be occupied until the approved scheme has been completed or provided on the site in accordance with the approved phasing. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, or upstream of, the permitted development.

Highway Informative 02

In accordance with Section 59 of the Highways Act 1980, please be considerate of causing damage to the existing highway during construction and implement mitigation measures as necessary. Should extraordinary expenses be incurred by the Highway Authority in maintaining the highway by reason of damage caused by construction traffic, the Highway Authority may seek to recover

these expenses from the developer.

Highway Condition 00

No development shall take place until a Construction Management Plan and Method Statement has been submitted to and approved in writing by the Local Planning Authority which shall indicate measures to mitigate against traffic generation and drainage of the site during the construction stage of the proposed development.

The Construction Management Plan and Method Statement shall include;

- phasing of the development to include access construction;
- the parking of vehicles of site operatives and visitors;
- loading and unloading of plant and materials;
- storage of plant and materials used in constructing the development;
- wheel washing facilities;
- the routes of construction traffic to and from the site including any off site routes for the disposal of excavated material and;
- strategy stating how surface water run off on and from the development will be managed during construction and protection measures for any sustainable drainage features. This should include drawing(s) showing how the drainage systems (permanent or temporary) connect to an outfall (temporary or permanent) during construction.

The Construction Management Plan and Method Statement shall be strictly adhered to throughout the construction period.

Highway Condition 21

No part of the development hereby permitted shall be occupied before the works to improve the public highway by means of road widening to all areas as shown on drawings LTP 4899 T2 00 01, T3 01 01, T1 01 04, 01 05, 01 06, 01 07 and 01 09 including 7 passing places to and from the substation and solar farm routes have been certified complete by the Local Planning Authority.

To ensure the provision of safe and adequate means of access to the permitted development.

Highway Informative 07

The highway improvement works referred to in the above condition are required to be carried out by means of a legal agreement between the landowner and the County Council, as the Local Highway Authority.

Case Officer:

Date: 9th September 2022

Dean Whitehead

for Warren Peppard

Head of Development Management

