

- Proposed Access Track
- Existing Gas Main
- Proposed Cable route
- Temporary Access Route
- Existing Public Right of Way
- Existing Bridleway
- Existing Permissive Footpath
- Proposed Fencing
- Proposed Inverter / Transformer
- Proposed Client Substation
- Proposed Communications Cabinet
- Proposed Pad Mount Transformer

Details:

Information by area		
No.	Modules	Capacity, kWp
1	11280	6542.400
2	41616	24137.280
3	21264	12333.120
4	12864	7461.120
5	33888	19655.040
Total	120912	70128.960

1.4 AC/DC Ratio = 25° Shading Angle  
Tilt Angle = 15°

02	Site Iterated to 70MW	JJ	MS	25.02.22
01	Compound and temp access added	SH	Checked	23.02.22

Rev: Amendment: Drawn: Checked: Date:

